



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLS2 080891 0008 Rev. 01

Initial No. CLS2 080891 0008 Rev. 00

**Certificate Holder:** TAK Products & Services Pte Ltd  
41 Sungei Kadut Avenue  
Singapore 729665  
SINGAPORE

UEN - 198903120Z

**Product:** Finishing Materials For Wall/Ceiling

**Brand Name:** Lamitak

**Model(s):** Lamitak

**Product Details:** Classification: C-s1, d0  
CIT<sub>G</sub> at 240 sec: 0.08; 0.04; 0.05  
CIT<sub>G</sub> at 480 sec: 0.01; 0.01; 0.01  
Thickness: 0.7mm  
Area Density: 1.008kg/m<sup>2</sup>  
Tested with the high pressure laminate adhered to a  
6mm thick calcium silicate board substrate

**Standard(s):** EN 13501-1:2007/A1:2009  
EN 45545-2:2013/A1:2015 Annex C

**Country of Origin:** India, Indonesia, People's Republic of China

**Test Report(s):** Refer to following page(s)

**Valid until:** 2025-03-10

Page 1 of 2

**Issued on:** 2020-09-25

Vice-President (Certification Department)  
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert). For more information on TÜV SÜD PSB Pte Ltd product certification: [www.tuv-sud-psb.sg](http://www.tuv-sud-psb.sg)



PSB Singapore

# CERTIFICATE OF CONFORMITY

No. CLS2 080891 0008 Rev. 01

Initial No. CLS2 080891 0008 Rev. 00

**Test Report(s):**

7191218496-MEC19/A1-JV\_CR1, 7191218496-MEC19/A2-JV\_CR1,  
TÜV SÜD PSB Classification 7191218496-MEC19/A3-JV\_CR1, 7191218496-MEC19/A4-JV\_CR1,  
7191218496-MEC19/B1-JV\_CR1, 7191218496-MEC19/B2-JV\_CR1,  
TÜV SÜD PSB Classification 7191218496-MEC19/B3-JV\_CR1, 7191218496-MEC19/B4-JV\_CR1,  
7191218496-MEC19/C1-JV\_CR1, 7191218496-MEC19/C2-JV\_CR1,  
TÜV SÜD PSB Classification 7191218496-MEC19/C3-JV\_CR1, 7191218496-MEC19/C4-JV\_CR1

Page 2 of 2

**Issued on:** 2020-09-25

Vice-President (Certification Department)  
TÜV SÜD PSB



This Certificate is the property of TÜV SÜD PSB Pte Ltd. Reports listed in this certificate is an integral part of the certificate and should be read in conjunction with it. The use of this Certificate is subjected to TÜV SÜD Group Testing and Certification Regulations; TÜV SÜD PSB Pte Ltd (PSB) General Terms and Conditions of Business and PSB Product Listing Scheme (PLS) Application Fact Sheet. The manufacturer is solely responsible for compliance of any product that has the same designation as the product type-tested. Persons relying on this Certificate should verify its validity by checking the e-directory: [www.tuvsud.com/ps-cert](http://www.tuvsud.com/ps-cert). For more information on TÜV SÜD PSB Pte Ltd product certification: [www.tuv-sud-psb.sg](http://www.tuv-sud-psb.sg)